

USER GUIDE

LITHIUM - ION AEROSOL DEVICE

INSTALLATION & USE OF YOUR DEVICE

MOBIAK S.A.
FACTORY: KATHIANA AKROTIRIOU
CHANIA - CRETE - GREECE

If you have any queries contact the Customer Services department at MOBIAK
www.mobiak.com



IN CASE OF INCIDENT

1. Get everybody out and well clear of danger.
2. If the incident escalates, then call the Fire Brigade
3. Close all doors on your way out. Do not stop to collect personal belongings.
4. REMEMBER - Personal safety comes first.
5. If the fire is small enough use your Lith-Ex Extinguisher.

NOTE - within 2 to 2.5 metres you the incident is intence and other means of fighting should be sought.

DURING USE

Lithium ion Battery Aerosol Devices are safe for use on all small personal devices.

Please check info on your product

1. Hold the can and shake. Whilst holding the handle remove the yellow safety wedge / safety pin.
2. Holding the device UPRIGHT, aim at base of the overheated battery fire from 2m to 2,5m, and press the lever.
3. Sweep from side to side, to cover the battery completely
4. Release lever to stop flow - check for any glowing embers
5. Leave the area and ventilate - Toxic fumes may have been generated

INSTALLATION

Always mount your extinguisher securely using the bracket provided.
Site the device where it can be seen, near to likely problem areas (adjacent to Li-ion devices)

MOST IMPORTANTLY site it where it can be reached easily in case of an overheating incident of Li-Ion batteries always ensuring the route to safety is clear.

WARNINGS

After application care should be taken as product residue may lead to significantly slippery surfaces and product should be cleaned from any surface with care.

MAINTENANCE

FACTORY SEALED UNITS

Li-ion aerosol device requires very little maintenance but should be checked at regular intervals as follows:

1. Check that the tamper seal tie and yellow wedge are in position and intact.
2. Ensure that the nozzle is not obstructed.

REFILLABLE UNITS

Your Li-Ion aerosol device is NOT refillable, it is one time use only.



NOTE

DO NOT PRE - TEST THE DEVICE THIS WILL RENDER IT INOPERATIVE

REMEMBER

- DO NOT TEST
- ALWAYS USE UPRIGHT
- ALWAYS KEEP IN BRACKET
- PROTECT FROM ROUGH USAGE

MOBIAK does not accept responsibility or warrant performance for part used Li-Ion aerosol devices or for those damaged by inappropriate storage or handling (please see user instructions for recommended practice).

Hand held aerosol devices are for first response (initial low ferocity) of incidents and are not suitable for larger ones.

MOBIAK does not accept responsibility for loss or damage to property or human life when Li-Ion aerosol devices are used and we do not give guarantee or warranty, or suggest, or imply that this product will be effective in all incidents regardless of the type or origin. We confirm that the agent has been 3rd party performance tested against a set performance criteria relating to overheat incidents. Further information relating to this testing can be found on the website www.mobiak.com

MOBIAK shall have no liability for any damage caused by the customer's failure to observe guidelines set out in the product user guide. This does not affect the customer's statutory rights.

For technical and MSDS information please go to www.mobiak.com

TRY TO KEEP YOUR EXIT ROUTE CLEAR IN CASE OF NEED OF EVACUATION