MOBIAK S.A. is Certified according to the following Quality Management Systems & Maritime Services:

CODE:	MBK09-250PA-H1B
ERP:	0135202

Trolley Fire Extinguisher 25Kg Dry Powder

Fire Extinguishers

Trolley Fire Extinguisher, 25Kg Dry Powder ABC 40%, with 5m Discharge Hose and Valve with Pressure Gauge Safety Release Mechanism. SILKSCREENED USAGE-MAINTENANCE INSTRUCTION LABEL 3rd Wheel added on the Front Side of the Fire Extinguisher Carriage for Easier Usage- Handling.

Soft Material is used in the retaining wreaths of the vessel to avoid injuries and oxidation

FIRE EXTINGUISHERS USER INSTRUCTIONS

CHARACTERISTICS	
Approval Type	GTC, ITALY, MED, MIRTEC
Extinguisher Type	Trolley
Pressure Type	Stored Pressure
Suppression Agent Type	Powder
Capacity	25Kg
Extinguishing Agent	ABC40%
Operating Temperature	-30 to +60 °C
Max Allowable Pressure	18 bar
Test Pressure	27 bar
Volume of Equipment	30 L
Cylinder Height	720±3 mm
Cylinder Diameter	250±1 mm
Cylinder Neck Thread	G2"
Valve Material	HPb59-1 (Nikel Plated)
Cylinder Material	DC01 (St12)
Safety Valve	22-28 bar
Approx. gross Weight	60,5 kg
Approx. Dimensions	1000x390 mm
Paint Finish	RAL 3000
Packaging Details	1 pc.

EN1866

Issue Date: 23/05/2024

Information may change

HEADQUARTERS: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, CRETE - GREECE, TEL.: +30 28210 63222, FAX :+30 28210 91644
ATHENS DISTRIBUTION CENTER: SHINEZA - ASPROPIRGOS, P.C. 19300, ATTICA - GREECE, TEL.: +30 210 4614006, FAX: +30 210 5595986
NORTH GREECE DISTRIBUTION CENTER: 8 ARKADIOU str. KALOCHORI - THESSALONIKI, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
CENTRAL & EAST CRETE DISTRIBUTION CENTER: P' str. INDUSTRIAL ZONE OF HERAKLION - CRETE - GREECE, P.C. 71601, TEL/ FAX: +30 2810 333151
www.mobiakfire.com